



EDINBURG CONSOLIDATED INDEPENDENT SCHOOL DISTRICT

Purchasing Department
411 N. 8TH Ave.
EDINBURG, TX 78541
PHONE: (956) 289-2311 FAX: (956) 383-7687

Gilbert Garza, Jr., Interim Superintendent

Dr. Rebecca Morrison, Deputy Superintendent

**ADDENDUM 1
CSP 20-19
SWIMMING POOL GAS BOILERS
October 29, 2019**

I. INSTRUCTIONS:

1. This addendum to Request for Proposals is issued after the receipt of bids. All changes covered in this addendum shall be included in your bid, and the addendum will be considered as one of the contract documents.
2. Proposers shall acknowledge receipt of this ADDENDUM as a signed attachment included with your bid if you haven't sent the bid.

II. PLEASE CHANGE:

Please see attached Pool Water Heater Schedule.

Respectfully Submitted,

Amaro Tijerina
Director of Purchasing

(Signature of authorized officer) Date

Company Name

Nondiscrimination Statement

It is the policy of Edinburg CISD not to discriminate on the basis of gender, age, handicap, religion, race, color, or national origin in its educational programs.
Es poliza del Distrito Escolar de Edinburg el no discriminar por razones con base en genero, edad, religion, raza, color origen nacional, ni discapacidad dentro de sus programas educacionales.

Communicate and Connect with All Stakeholders

Innovate Through Technology



Secure a Safe Learning Environment



Develop and Retain Highly Qualified Staff

Excel in Academics and Ensure Equal Access

POOL WATER HEATER SCHEDULE

MARK	PWH-1,2
FUEL	NAT. GAS
STYLE	NON-CONDENSING
INPUT MBH	1,999
OUTPUT MBH	1,679
TURNDOWN RATIO	4:1
GPM	113.0
EWT/LWT (°F)	140/170
THERMAL EFFICIENCY	84%
MAX. PRESSURE DROP (FT. HD.)	10
FLUE SIZE	14
VOLTAGE/PHASE/FREQUENCY	120/1/60
MANUFACTURER	Raypak
MODEL NUMBER	Hi Delta 2002C
OPERATING WEIGHT (LBS)	-
SHIPPING WEIGHT (LBS)	
NOTES	1,2,3,4,5

NOTES:

1. BOILER MUST MEET LATEST LOW NOx REQUIREMENTS FOR TEXAS.
2. PROVIDE WITH CONSTANT FLOW CIRCULATING PUMP. COORDINATE WITH MANUFACTURER FOR HEAD
3. PROVIDE BOILER CONTROLLER WITH BACNET INTERFACE CARD FOR INTEGRATION WITH EXISTING BAS.
4. PROVIDE CATEGORY IV STAINLESS STEEL COMBUSTION EXHAUST VENT SIZED AS INDICATED.
5. PROVIDE WITH MOTORIZED LOW TEMPERATURE VALVE TO ENSURE THAT ENTERING WATER TEMPERATURES REMAIN ABOVE THE LOW LIMIT FOR NON-CONDENSING BOILER OPERATION.
6. PROVIDE OUTDOOR VENT KIT WITH COLLAR ASSEMBLY AND AIR INTAKE COVER
7. PROVIDE OFS SP2-4500K POOL AND SPA HEAT EXCHANGER
8. PROVIDE FLOW SWITCH AND AUTO RESET HI LIMIT SWITCH
9. PROVIDE BLADDER TYPE EXPANSION TANK