

**ADDENDUM No. 1 LINCOLN ELEMENTARY PURCHASE OF REFRIGERATED AC UNITS PROJECT
EDINBURG CONSOLIDATED INDEPENDENT SCHOOL DISTRICT**

DATE: March 6, 2019

BID DATE: March 19, 2019

NOTICE:

- A. *The following changes, omissions or alterations to the specification and drawings shall be made insofar as the specifications and drawings are inconsistent with following, this addendum shall govern.*
 - B. *Acknowledge receipt of this addendum by inserting its number and date of issue in the place provided for same in the proposal. This addendum forms a part of the Contract Documents.*
 - C. *It is imperative that this addendum be inserted INTO set of specifications.*
-

Item No. 1 AC units efficiency:

- A. Units shall have a minimum efficiency of 16 SEER

Item No. 2 To Add electric heating elements:

- A. All AC units shall include electric heating elements and sized according to unit size and capacity.

Item No. 3 To Add ECM motors:

- A. All AC units shall include Electronically Commutated Motors (ECM)

Item No. 4 Coil type:

- A. Preferred finned coils in condenser unit (copper tube with aluminum fins)

Item No. 5 Design temperatures:

- A. Condenser: Minimum Outdoor/ Ambient at 105 F
- B. EAT: 75 F ; LAT: 55 F

Item No. 6 AC system type:

- A. All AC units shall be Straight Cool Systems

Item No. 7 Electric Heat Requirements:

- A. AC 2-3 Ton: 10 kW
- B. AC 4 Ton: 15 kW
- C. AC Office: 15 kW
- D. AC Cafeteria: 15 kW
- E. Library: 20 kW